Pulsar®
www.pulsar.pl
www.zasilacze.pl

INSTALLATION GUIDE
ENGLISH
Code: **ARADIN2**
Name: **Enclosure with a DIN rail for RACK cabinets, 24xS, 160mm deep**

IM ARADIN2

Edition: 3nd from 17.07.2020
Supersedes: 2st from 02.07.2014

1. Intended use: EN*

The enclosure with a DIN rail for RACK cabinets is intended for mounting equipment located inside DIN enclosures, for RACK 19'' cabinets. The enclosure features a DIN rail, length: 24x1S. The height of the mounted module cannot exceed 160mm. The enclosure can accommodate max. 24 fuses, 1 S wide. Six M6 screws with cage nuts for mounting in RACK cabinets are included. The enclosure features a 420x20 mm labeling field.

2. Specifications:

SPECIFICATIONS	
Mounting dimensions	**RACK cabinet:** W=19", H=3U **number of fuses:** 24x1S
Dimensions	**W=482, H=131, D=235 [mm, +/-2]** **W_1=435, W_2=444, D_1=70, D_2=162 [mm, +/-2]**
Operation temperature range	**- 10°C ÷ +40°C**
Net/gross weight	**3,75 / 3,96 [kg]**
Materials	**sheet metal DC01, 1,0mm thick** **rust protection** **colour: RAL 9005 BLACK**
Use	**inside**
Closing	**bolted**
Notes	**- the enclosure can accommodate max. 24 fuses, 1 S wide** **- six-point fixing to the front RACK rails** **- 6 M6 screws + cage nuts included** **- the enclosure features a 420x20 mm labeling field**
Declarations	**RoHS**

3. Dimensions:



4. Enclosure:





MANUFACTURER
Pulsar K.Bogusz Sp.j.
Siedlec 150,
32-744 Łapczyca, Poland
Tel. (00 48) 14-610-19-40, Fax. (00 48) 14-610-19-50
e-mail: biuro@pulsar.pl
www.pulsar.pl , www.zasilacze.pl

WARRANTY
24 months from the date of purchase.
THE WARRANTY IS VALID only upon presentation of the item's proof of purchase.