

Supersedes: -----


### 1. Intended use:

The RACK 19" cabinet enables integrating CCTV, AC, I&HAS, RTV, LAN, or other systems in medium and big companies. It is intended for devices manufactured in enclosures of the 19" standard. Due to the RACK cabinets, the devices are aesthetically mounted and protected against mechanical damage.

### 2. Specifications:

SPECIFICATIONS					
Mounting dimensions:	W=19", H=42U, D=582mm				
External dimensions:	W=800, H=2055, D=800 [mm, +/-2]				
Net/gross weight:	123 / 129 [kg]				
Materials:	<ul> <li>RACK mounting rails: cold-rolled steel SPCC 2mm RAL 9004 - bolted</li> <li>horizontal mounting rails: cold-rolled steel SPCC 1,5mm - bolted</li> <li>frame: cold-rolled steel SPCC 1,2mm RAL 9004 - welded</li> <li>front door: 5mm toughened glass / SPCC 1,2mm RAL 9004 - hinged</li> <li>side panel: cold-rolled steel SPCC 1,2mm RAL 9004 - removable</li> <li>rear door: cold-rolled steel SPCC 1,2mm RAL 9004 - hinged</li> </ul>				
Static load:	1000 kg (with leveling feet)				
Use:	inside, IP20				
Notes:	<ul> <li>adjustable distance between front and rear RACK rails</li> <li>ventilation holes in the top and bottom panel</li> <li>possible mounting of a fan unit in the top panels - RAWP (max. 3 pcs.)</li> <li>cable ducts in the top and bottom panel</li> <li>two cable management panels, vertical, mounted in front of cabinet</li> <li>4 casters without locks and 4 leveling feet included</li> <li>possible assembly of a 100mm high plinth - RAC188M</li> <li>lockable front door (2 keys in set)</li> <li>lockable rear door (2 keys in set)</li> <li>side panel - lock assembly possible - RAZB16</li> <li>ready-to-assemble</li> </ul>				
Declarations, warranty:	RoHS, 12 months from the date of purchase				

## 3. Structure of the RACK cabinet.



# EN

# 4. Components

Nu mb er	Component	Amou nt	Foto	Nu mb er	Component	Amou nt	Foto
1	Top panel	1 pcs.		13	Lock- rear door RAZ25	1 pcs.	3
2	Bottom panel	1 pcs.		14	Side door distance	4 pcs.	6
3	Front doors	1 pcs.		15	"2" wheel without lock"	4 pcs.	
4	Rear door	1 pcs.		16	Leveling foot	4 pcs.	į
5	Side panel	2 pcs.		17	M8x12 Head Cap Screw	16 pcs.	
	Cabinet			18	M8 nut	16 pcs.	Ø
6	frame	2 pcs.		19	10mm Phillips	92	
7	Horizontal rail	6 pcs.	Constant of the owner of the		screw	pcs.	
8	Distance	12 pcs.		20	M5 nut, spring washer	2 pcs.	00000000000000000000000000000000000000
9	RACK 19" 42U rail	4 pcs.		21	Spacer for front/rear doors	2 pcs.	0
10	Cable management panel, vertical	2 pcs.	and the second second	22	M6x12 Phillips screw	40 pcs.	
11	Cable gland end cup (upper)	2 pcs.		23	M6 nut ("cage nut")	40 pcs.	
12	Cable gland end cup (lower)	2 pcs.		24	Cross / hexagon wrench	1 pcs.	

The free standing, ready-to-assemble RACK cabinet is delivered in 5 separate packages.

**5.1)** Place horizontally two RACK cabinet frames with both top and bottom plates. Pay attention to the grounding in the frame - as shown in the drawing



Top panel - lens



Bottom panel - back



Bottom panel - lens

**5.2)** Mount the top plate and bottom plate to the left and right frames of the RACK cabinet, respectively. Use M8x12 Head Cap Screws with M8 nuts (16pcs). Screw the cabinet **wheels** and **legs** to the bottom plate of the cabinet.




5.3) Place the RACK cabinet vertically and mount:


- Cable gland end cups (up and down) -screw 10mm (black) 12pcs
- side door distance screw 10mm 4pcs



5.4) Mount to frames (in front and back) cross profiles, distances and RACK profiles as shown below.









5.6) Installation of front, rear, and side doors














<i>MANUFACTURER</i> <b>Pulsar sp. j.</b> Siedlec 150,	
32-744 Łapczyca	
Tel. 14-610-19-40, Fax. 14-610-19-50	
e-mail: <u>biuro@pulsar.pl</u> , <u>sales@pulsar.pl</u>	
http:// <u>www.pulsar.pl</u> , <u>www.zasilacze.pl</u>	